



- NOTES:**
- DO NOT BACKFILL UNTIL ALL BRASS FITTINGS HAVE BEEN INSPECTED BY THE DISTRICT.
  - SERVICE SIZES ARE 1" UNLESS OTHERWISE DESCRIBED IN THE SPECIFICATIONS.
  - METER BOX SHALL BE:
    - IN AREAS WITH ROLLED CURB OR METER BOX IN DRIVEWAY, USE MIDSTATES BOX #MS-BCF-1521-12-B WITH READER LID #MS-BCF-1521-RLA
    - IN AREAS WITH VERTICAL CURB OR METER BOX BEHIND SIDEWALK, USE CARSON STANDARD PLASTIC METER BOX #1220-12L WITH READER LID.
  - INSTALL WATER SERVICE MARKER POST ABOVE END OF SERVICE TAIL-PIECE. THE POST SHALL BE 2"x 4" WITH THE 18" ABOVE GRADE PAINTED BLUE ON ALL SIDES. STENCIL "WATER" IN 2" LETTERS WITH BLACK PAINT.

**ROTH HILL**

Roth Hill, LLC  
 11130 NE 33rd Place,  
 Suite 200  
 Bellevue, WA 98004  
 Tel. 425.869.9448

**TYPICAL SERVICE DETAIL  
 SINGLE SERVICE**



PLOTTING DATE SEPT. 2010	DRAWN TVW	CHECKED LDS	APPROVED JFK	DISTRICT TNH
PLOTTING SCALE NTS: 1=1	FILE NAME F:\DETAILS\WD90\WATER\0003	DATE APPROVED 1/13/11		

WATER DISTRICT NO.90

DWG. NO.

3