



NOTES:

1. DO NOT BACKFILL UNTIL ALL BRASS FITTINGS HAVE BEEN INSPECTED BY THE DISTRICT.
2. SERVICE SIZES ARE 1" UNLESS OTHERWISE DESCRIBED IN THE SPECIFICATIONS.
3. METER BOX SHALL BE:
 - A. IN AREAS WITH ROLLED CURB OR METER BOX IN DRIVEWAY, USE CARSON HEAVYWALL BOX #BCF-1324 WITH READER LID #BCF-1324-RLA
 - B. IN AREAS WITH VERTICAL CURB OR METER BOX BEHIND SIDEWALK, USE CARSON STANDARD PLASTIC METER BOX #1220-12L WITH READER LID.
4. INSTALL WATER SERVICE MARKER POST ABOVE END OF SERVICE TAIL-PIECE. THE POST SHALL BE 2"x 4" WITH THE 18" ABOVE GRADE PAINTED BLUE ON ALL SIDES. STENCIL "WATER" IN 2" LETTERS WITH BLACK PAINT.



Stantec
 11130 NE 33rd Place,
 Bellevue WA 98004
 phone: (425) 869-9448

TYPICAL SERVICE DETAIL SINGLE SERVICE				
PLOTTING DATE OCT 2017	DRAWN TVW	CHECKED	APPROVED	DATE APPROVED
SCALE NTS	FILE NAME R:\cad\detail\autocad\WD90\WATER\3_single_service_detail.dwg			



WATER DISTRICT NO.90

DWG. NO.	3
----------	----------