


**NOTES:**

1. ALL FITTINGS SHALL BE BRASS CONFORMING TO AWWA C800.
2. ALL HORIZONTAL RUNS OF PIPE SHALL BE COPPER OR BRASS EXCEPT WHERE OTHERWISE NOTED. ALL VERTICAL RUNS SHALL BE BRASS EXCEPT WHERE OTHERWISE NOTED. ALL BRASS SHALL CONFORM TO AWWA C800.
3. ALL ABOVE GROUND GALV. TO BE PAINTED FARWEST PAINT CASE YELLOW PN# X3472, TWO COATS.
4. SWING JOINTS SHALL BE DOUBLE STREET ELBOWS OR 2 90° BENDS & NIPPLES.

|   |  |                                  |                               |                                |   |
|---|--|----------------------------------|-------------------------------|--------------------------------|---|
| <p><b>ROTH HILL</b></p> <p>Roth Hill, LLC<br/>11130 NE 33rd Place,<br/>Suite 200<br/>Bellevue, WA 98004<br/>Tel. 425.869.9448</p> | <p><b>3" AIR/VAC VALVE ASSEMBLY<br/>FOR 10" &amp; LARGER MAINS</b></p> |                                  |                               |                                |  <p>WATER DISTRICT NO.90</p> |
|   | <p>PLOTTING DATE<br/>SEPT. 2012</p>                                    | <p>DRAWN<br/>TWV</p>             | <p>CHECKED<br/><i>CDS</i></p> | <p>APPROVED<br/><i>LPF</i></p> |   |
| <p>PLOTTING SCALE<br/>NTS</p>   | <p>FILE NAME<br/>F:\DETAILS\WD90\WATER\0016</p>                        | <p>DATE APPROVED<br/>9-18-12</p> |                               | <p>DWG. NO.<br/>16</p>         |   |