

**NOTES:**

1. ALL FITTINGS SHALL BE BRASS CONFORMING TO AWWA C800.
2. ALL HORIZONTAL RUNS OF PIPE SHALL BE COPPER OR BRASS EXCEPT WHERE OTHERWISE NOTED. ALL VERTICAL RUNS SHALL BE BRASS EXCEPT WHERE OTHERWISE NOTED. ALL BRASS SHALL CONFORM TO AWWA C800.
3. ALL ABOVE GROUND GALV. TO BE PAINTED FARWEST PAINT CASE YELLOW PN# X3472, TWO COATS.
4. SWING JOINTS SHALL BE DOUBLE STREET ELBOWS OR 2 90° BENDS & NIPPLES.

DOUBLE STRAP SADDLE (ROMAC 202S OR SMITH-BLAIR, 2" IPT)


WATERMAINS 12" & SMALLER

**ROTH HILL**

Roth Hill, LLC  
11130 NE 33rd Place,  
Suite 200  
Bellevue, WA 98004  
Tel. 425.869.9448

**2" AIR/VAC VALVE ASSEMBLY  
FOR 12" & SMALLER MAINS**

PLOTTING DATE APRIL 2013	DRAWN QND	CHECKED	APPROVED	DISTRICT
PLOTTING SCALE NTS: 1=1	FILE NAME F:\DETAILS\WD90\WATER\0018	DATE APPROVED		



WATER DISTRICT NO.90

DWG. NO.

18