



ELEVATION

END VIEW

NOTE 1:

1-1/2" DISK METER = 13-1/4"
 2" COMPOUND METER = 15-1/4"

NOTE 2:

1 1/2" DISK METER = 8"
 2" COMPOUND METER = 18"

NOTE 3:

COMPRESSION PACK JOINT:
 FOR 1-1/2" DIA. USE FORD #C84-66 (PACK END C.T.S.) OR EQUAL.
 FOR 2" DIA. USE FORD #C84-77 (PACK END C.T.S.) OR EQUAL.

NOTE 4:

METER BOXES SHALL BE INSTALLED AS FOLLOWS:
 2- NO. 3 METER BOX BOTTOMS STACKED UPON EACH OTHER
 1- NO. 3 SOLID METER BOX LID AS DESCRIBED IN GENERAL NOTES.

GENERAL NOTES:

1. FORD CUSTOM SETTER #B-95082-012.
2. METERS TO BE SUPPLIED AND SET BY THE DISTRICT
3. ABOVE REFERENCED PART NUMBERS REFER TO ITEMS MANUFACTURED BY FORD METER BOX CO, INC. THESE OR EQUIVALENT FITTINGS TO BE USED.
4. METER SETTER TO BE APPROVED BY THE DISTRICT PRIOR TO BACKFILL.
5. METER BOXES TO BE SUPPLIED BY OWNER/CONTRACTOR. METER BOX SHALL BE OF PRECAST CONCRETE FOGTITE NO. 3 WITH A SOLID CONCRETE LID WITH LIFT HANDLES AT EACH END OR EQUAL WITH READER LID IF METER BOXES ARE LOCATED IN A HIGH TRAFFIC AREA AN ALTERNATE MAY BE NEEDED AND APPROVED BY THE DISTRICT.
6. ALL BRASS PIPE AND FITTINGS SHALL CONFORM TO AWWA C800.

ROTHHILL

Roth Hill, LLC
 11130 NE 33rd Place,
 Suite 200
 Bellevue, WA 98004
 Tel. 425.869.9448

1-1/2" & 2" METER SETTERS



WATER DISTRICT NO.90

PLOTTING DATE JUNE 2012	DRAWN TVW	CHECKED LDS	APPROVED ZSF	DISTRICT JAD
PLOTTING SCALE NTS: 1=1	FILE NAME F:\DETAILS\WD90\WATER\0022	DATE APPROVED 11-22-11		

DWG. NO. 22