



NOTE FOR FIRE SPRINKLER DCVA'S:  
 DCVA SIZE TO BE SPECIFIED BY THE FIRE SPRINKLER SYSTEM DESIGNER (1" MIN.). PROPOSED VALVE & SIZE IS TO BE SUBMITTED TO KCWD NO. 90 IN WRITING PRIOR TO INSTALLATION.

NOTE:  
 DETERMINATION OF DCVA OR RPBA FOR CROSS CONNECTION CONTROL WILL BE MADE BY WD NO. 90 ON A CASE BY CASE BASIS.



Engineering Partners, LLC

2600 116th Avenue NE #100  
 Bellevue, Washington 98004  
 Tel 425.869.9448

## CROSS CONNECTION CONTROL-DCVA

PLOTTING DATE JAN. 2005	DRAWN DSH	CHECKED	APPROVED <i>[Signature]</i>	DISTRICT <i>T.N.H.</i>
PLOTTING SCALE NTS: 1=1	FILE NAME F:\DETAILS\WD90\WATER\0024	DATE APPROVED <i>2-03-05</i>		



WATER DISTRICT NO.90

DWG. NO. 24