



NOTES :

- ① COUPLING: ASBESTOS-CEMENT (A/C) BY DUCTILE IRON (DUCTILE IRON, ROMAC STYLE 501, OR EQUAL).
- ② DUCTILE IRON PIPE, CL. 52, DIAMETER TO MATCH EXISTING A/C.
- ③ BACKFILL EXISTING A/C AND COUPLING WITH PEA GRAVEL TO 1' ABOVE PIPE.
- ④ BACKFILL UNDER WATERLINE WITH CRUSHED ROCK COMPACTED TO 95% MDD, OR CONTROL DENSITY FILL (CDF) PER KING COUNTY MATERIAL REQUIREMENTS.
- ⑤ BACKFILL OVER THE TOP OF THE WATERLINE SHALL BE CRUSHED ROCK COMPACTED TO 95% MDD, OR CONTROL DENSITY FILL (CDF) PER KING COUNTY MATERIAL REQUIREMENTS, WITHIN COUNTY ROAD TRAVEL SURFACE. BACKFILL OVER THE TOP OF THE PIPE WITH NATIVE MATERIAL COMPACTED TO 90% MDD IF LOCATED WITHIN EASEMENT OR UNIMPROVED AREA.
- ⑥ A/C DISPOSAL PER WAC173-400-075, WAC 296-65, PUGET SOUND AIR POLLUTION CONTROL AGENCY REQUIREMENTS.

RothHill

Engineering Partners, LLC

28800 118th Avenue NE #1000
 Bellevue, Washington 98004
 Tel: 425 889 9448

**A/C WATER MAIN REPLACEMENT
 @ SANITARY SEWER CROSSING**

PLOTTING DATE JAN. 2005	DRAWN DSH	CHECKED KRG	APPROVED <i>T.N.H.</i>	DISTRICT T.N.H.
PLOTTING SCALE NTS 1=1	FILE NAME F:\DETAILS\WD90\WATER\0031	DATE APPROVED 3-12-04		



WATER DISTRICT NO.90

DWG. NO. 31