

NOTES:


LENGTH AS REQUIRED TO PUT OPERATING NUT, 24"–30" FROM SURFACE. EXTENSIONS ARE REQUIRED WHEN THE VALVE NUT IS MORE THAN FOUR (4) FEET BELOW FINISHED GRADE. EXTENSIONS ARE TO BE A MINIMUM OF TWO (2) FEET LONG. ONE EXTENSION IS TO BE USED PER VALVE.

ALL EXTENSIONS ARE TO BE MADE OF STEEL, SIZED AS NOTED, AND PAINTED WITH TWO (2) COATS OF METAL PAINT.



Engineering Partners, LLC
 2600 116th Avenue NE #100
 Bellevue, Washington 98004
 Tel 425.869.9448

VALVE OPERATING NUT EXTENSION



WATER DISTRICT NO.90

PLOTTING DATE MAY 2009	DRAWN DSH	CHECKED LDS	APPROVED <i>JSF</i>	DISTRICT <i>TNH</i>
PLOTTING SCALE NTS: 1=1	FILE NAME F:\DETAILS\WD90\WATER\0036	DATE APPROVED <i>5/18/09</i>		

DWG. NO. 36