

ELEVATION


NOTE:

ALL SADDLES, SERVICE LINE AND METER SETTERS SHALL BE 2" MATERIAL FROM THE SADDLE AND THROUGH THE DISCHARGE TAIL PIECE. THE DISTRICT WILL SUPPLY THE METER AND ADAPTERS NECESSARY FOR 1.5" SERVICE

PARTS FOR 1 1/2" AND 2" SERVICE

1. 2" SERVICE SADDLE. TYPE BY WATER MAIN MATERIAL - SEE STANDARD SPECIFICATIONS
2. FORD PACKJOINT COUPLINGS/PLASTIC PIPE
3. SETTERS: 2" FORD VBH77-XXB-11-77-NL LENGTH WITH LOCKING BYPASS (SETTER LENGTH WILL BE DETERMINED BY DISTRICT)
4. CONCRETE METER BOX WITH STEEL COVER AND METER LID FOGTITE NO. 2. INCLUDE HOLE FOR METER ANTENNA
5. GATE VALVE: 2 INCH-RESILIENT WEDGE SEATED (APWA C-509)
6. CAST IRON VALVE BOX WITH COVER
7. WATER SERVICE LINE IPS HDPE SDR 7 4710, ASTM D-2239

Plot Date: 4/24/2025 1:13 PM By: jsh koala
 Save Date: 4/24/2025 1:11 PM By: jsh File: P:\V\DWG\00001000\FD\00\FD\00\Standard Documents\Standard Details\CDWV00G_DETAIL5.DWG



STANDARD DETAIL
 NTS
1 1/2" AND 2" WATER SERVICE



Rev. Date
 04/2025
 DETAIL NO.
5