


LEVEL WITH BONNET
FLANGE OF FIRE HYDRANT

INSTALL ONLY
WHERE/WHEN
IDENTIFIED ON PLANS


CONC. BACKFILL TO 6" FROM
GROUND WHERE SPECIFIED.
EARTH BACKFILL COMPACTED
IN 6" LAYERS ELSEWHERE.

FIRE HYDRANT BOLLARDS SHALL BE 9"
DIA. BY 6' LONG PRECAST CONC. POST
EQUAL TO FOG-TITE METER SEAL CO.
PAINT WITH TWO COATS OSHA SAFETY
YELLOW, ENAMEL.




ELEVATION VIEW

3' MIN. RADIUS OF LEVEL
GROUND AROUND FIRE
HYDRANT




PLAN VIEW

FIRE HYDRANT BOLLARD POST



FRONT VIEW
(FOR GATE VALVE)

PAINT TYPE AND SIZE OF VALVE
AND DISTANCE FROM THE
VALVE MARKER TO THE VALVE
ON THE POST WITH NEATLY
STENCILED WHITE ENAMEL
NUMBERS, 1" IN HEIGHT.



VALVE MARKER POST

NOTES:

1. VALVE MARKERS TO BE USED FOR BLOW-OFF AND MAINLINE VALVES OUTSIDE PAVED AREAS.
2. MARKER POSTS SHALL BE TRIVIEW FLEX 66 BLUE WITH WARNING LABEL.

P:\DWG\4/24/2025 1:13 PM By: Josh Kozak
 Save Date: 4/24/2025 1:13 PM Dwg: 23a File: P:\K\K\DWG\2025\01\06\06\NF\66\Ref\Standard Detail\CD\W990_DETALS.DWG



**DAVID EVANS
AND ASSOCIATES INC.**

STANDARD DETAIL

NTS

MARKER AND
BOLLARD POST



Water District No. 90

Rev. Date
04/2025

DETAIL NO.

13