



**NOTES:**

1. ALL FITTINGS SHALL BE BRASS CONFORMING TO AWWA C800
2. ALL HORIZONTAL RUNS OF PIPE SHALL BE COPPER OR BRASS EXCEPT WHERE OTHERWISE NOTED. ALL VERTICAL RUNS SHALL BE BRASS EXCEPT WHERE OTHERWISE NOTED. ALL BRASS SHALL CONFORM TO AWWA C800.
3. ALL ABOVE GROUND GALV, TO BE PAINTED FARWEST PAINT CASE YELLOW PN#X3472, TWO COATS.
4. SWING JOINTS SHALL BE DOUBLE STREET ELBOWS OR 2 90° BENDS AND NIPPLES.



DAVID EVANS AND ASSOCIATES, INC.

STANDARD DETAIL  
3" AIR/VAC VALVE ASSEMBLY



KING COUNTY WATER DISTRICT NO. 90

Rev. Date 11/12/21  
DETAIL NO.

16