



ELEVATION

NOTE:

AN INDIVIDUAL PRV IS OWNED AND MAINTAINED BY THE PROPERTY OWNER. THE DISTRICT REQUIRES THAT THE OWNER PROVIDE A PRV (INSTALLED AT A LOCATION OF THEIR CHOOSING) ANYTIME THAT THE WATER PRESSURE AT THE POINT OF SERVICE (I.E. RESIDENCE LOWER FLOOR) WOULD OTHERWISE EXCEED 80 PSI FROM THE DISTRICT'S LOCAL PRESSURE ZONE. FAILURE TO PROPERLY INSTALL AND PERIODICALLY TEST AND MAINTAIN THE PRV MAY LEAD TO PROPERTY DAMAGE THAT WILL BE THE SOLE RESPONSIBILITY OF THE PROPERTY OWNER. THE DISTRICT RECOMMENDS THAT INDIVIDUAL PRV'S BE ADJUSTED TO DELIVER BETWEEN 40 AND 60 PSI AT THE POINT OF SERVICE.

Plot Date: 4/24/2025 1:13 PM By: Josh Kouls
 Save Date: 4/24/2025 1:11 PM By: jcb File: P:\K\DW\02020108\01\NFCV_RedStandard_Documents\Standard Detail\CAD\DW90_DETAIL.S.DWG



**DAVID EVANS
AND ASSOCIATES INC.**

STANDARD DETAIL

NTS

INDIVIDUAL PRESSURE REDUCING VALVE (PRV)



Water District No. 90

Rev. Date
04/2025

DETAIL NO.

20