



NOTES:

1. HILLHOLDER PIPE ANCHORS REQUIRED ON SLOPES MORE THAN 20%.
2. SPACING AS APPROVED BY THE DISTRICT ENGINEER.
3. RESTRAINED JOINTS REQUIRED ON WATER MAIN.
4. LOCATE PIPE ANCHOR (DEADMAN) ON DOWN HILL SIDE OF PIPE BELL WHEN PRACTICAL.
5. REINFORCEMENT: MIN. #4 HOOP BAR, CENTERED, 3" CLEAR FROM OUTER EDGES.

Plot Date: 4/24/2025 1:13 PM By: John Koculis
 Save Date: 4/24/2025 1:11 PM By: John Koculis
 File: P:\P\WC\W090201\090201\090201\090201\Standard Detail\CAW090201\DETAILS.DWG



**DAVID EVANS
AND ASSOCIATES INC.**

STANDARD DETAIL

NTS

**PIPE ANCHOR
(DEADMAN)**



Water District No. 90

Rev. Date
04/2025

DETAIL NO.

30