



NOTES:

1. ALL FITTINGS SHALL BE BRASS CONFORMING TO AWWA C800.
2. ALL HORIZONTAL RUNS OF PIPE SHALL BE COPPER OR BRASS EXCEPT WHERE OTHERWISE NOTED. ALL VERTICAL RUNS SHALL BE BRASS EXCEPT WHERE OTHERWISE NOTED. ALL BRASS SHALL CONFORM TO AWWA C800.
3. ALL ABOVE GROUND GALV. TO BE PAINTED FARWEST PAINT CASE YELLOW PN #X3472, TWO COATS.
4. SWING JOINTS SHALL BE DOUBLE STREET ELBOWS OR TWO (2) 90° BENDS AND NIPPLES.

Plot Date: 4/24/2025 1:13 PM By: Josh Kovach
 Save Date: 4/24/2025 1:11 PM By: Jobi File: P:\K\CD\W090000106\KINFCIO-RedStandard Documents\Standard Details\CAD\W090_DET\ALS.DWG



**DAVID EVANS
AND ASSOCIATES INC.**

STANDARD DETAIL

NTS

**2" AIR/VAC VALVE ASSEMBLY
W/ BLOW-OFF
(HDPE WATER MAIN)**



Water District No. 90

Rev. Date
04/2025

DETAIL NO.

18B