

**THE TEXT BELOW IS TO BE INCLUDED ON THE CONSTRUCTION DRAWINGS.**

GENERAL NOTES:

1. ALL CONSTRUCTION SHALL CONFORM TO THE REQUIREMENTS OF KING COUNTY WATER DISTRICT NO. 90 (DISTRICT), THE DISTRICT'S TECHNICAL SPECIFICATIONS AND STANDARD DETAILS, THE LOCAL ROADWAY AGENCY, AND THESE DRAWINGS.
2. THE LOCATION OF THE EXISTING UTILITIES SHOWN ON THE DRAWING IS APPROXIMATE. LOCATION AND PROTECTION OF UNDERGROUND UTILITIES SHALL BE IN ACCORDANCE WITH CHAPTER 19.122 RCW. CALL (800) 424-5555 AT LEAST TWO (2) BUSINESS DAYS BEFORE ANY EXCAVATION.
3. REPLACE ANY DAMAGED OR DESTROYED SURVEY MONUMENTS.
4. THIS PLAN AND PROFILE INFORMATION HAS BEEN FURNISHED BY THE DEVELOPER OR THEIR ENGINEER.
5. MINIMUM SEPARATION BETWEEN SANITARY SEWER AND POTABLE WATER LINES SHALL BE 10 FEET HORIZONTALLY (MEASURED SIDE TO SIDE) AND 18 INCHES VERTICALLY FROM BOTTOM OF WATER LINE TO CROWN OF SEWER. MIN. VERTICAL SEPARATION FOR PERPENDICULAR OR OBLIQUE CROSSINGS SHALL BE 3 FEET FROM OUTSIDE EDGES. SITUATIONS THAT REQUIRE LESS THAN MIN. SEPARATION SHALL BE CONSTRUCTED IN ACCORDANCE WITH DOE'S "CRITERIA FOR SEWAGE WORKS DESIGN", LATEST EDITION.
6. THE DEVELOPER SHALL BE RESPONSIBLE FOR ACQUIRING ALL NECESSARY EASEMENTS, AGREEMENTS, AND PERMITS PRIOR TO CONSTRUCTION.
7. A PRE-CONSTRUCTION MEETING IS REQUIRED. CALL THE DISTRICT AT (425) 255-9600 TO SCHEDULE PRIOR TO PERFORMING ANY WORK.
8. THE CONTRACTOR SHALL NOTIFY THE DISTRICT AT LEAST SEVEN (7) DAYS IN ADVANCE AND MAKE THE NECESSARY ARRANGEMENTS WITH THE DISTRICT INSPECTOR BEFORE CONNECTING TO THE EXISTING WATER SYSTEM.
9. WATER SHUTOFFS REQUIRE A MIN. OF 72 HOURS PRIOR NOTIFICATION TO AFFECTED CONNECTION.
10. THE CONTRACTOR IS REQUIRED TO PROVIDE A COMPETENT PERSON(S) TRAINED TO IDENTIFY EXISTING OR PREDICTABLE HAZARDS RELATED TO TRENCH SAFETY, SOIL CONDITIONS, AND SHORING REQUIREMENTS, IN ACCORDANCE WITH WAC 296-155.

CAUTION - EXTREME HAZARD - OVERHEAD ELECTRICAL SERVICE LINES ARE GENERALLY NOT SHOWN ON THE DRAWINGS. ELECTRICAL LINES SHOWN ON THE DRAWINGS ARE LOCATED BY POINT-TO-POINT, POWER-POLE-TO- POWER-POLE CONNECTION. THE CONTRACTOR IS RESPONSIBLE FOR DETERMINING THE EXTENT OF ANY HAZARD CREATED BY OVERHEAD ELECTRICAL POWER IN ALL AREAS AND SHALL FOLLOW PROCEDURES DURING CONSTRUCTION AS REQUIRED BY LAW AND REGULATION. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL MEET WITH UTILITY OWNERS AND DETERMINE THE EXTENT OF HAZARD AND REMEDIAL MEASURES, AND SHALL TAKE WHATEVER PRECAUTIONS MAY BE REQUIRED.

Plot Date: 4/24/2025 1:13 PM By: Josh Kozals  
Save Date: 4/24/2025 1:11 PM By: jko  
File: P:\KINGCOUNTY\001\0000\NFO\Ref\Standard Documents\Standard Detail\SDWG



**DAVID EVANS  
AND ASSOCIATES INC.**

**STANDARD DETAIL**

NTS

**DEVELOPER EXTENSION  
STANDARD PLAN NOTES**



Water District No. 90

Rev. Date  
04/2025  
DETAIL NO.

**10**