



#### NOTES:

1. 1" CC THREAD SERVICES SADDLE, TYPE BY WATER MAIN MATERIAL - SEE STANDARD SPECIFICATIONS.
2. 1" BRASS CORP STOP (FORD FB1001-4-U2-ANWT-NL OR APPROVED EQUAL).
3. 1" CENTENNIAL PLASTICS INC. CENCORE HIGH DENSITY POLYETHYLENE SERVICE PIPE MEETING AWWA C901 REQUIREMENTS; ASTM D2239, SDR 7 PRESSURE CLASS 250 PSI, I.P.S.
4. NO SPLICES ALLOWED IN SERVICE LINES.
5. 1" 45 DEGREE BRASS ELBOW. INCLUDE WITH 1" 45 DEGREE 1" BRASS MIPxULTRA TITE ADAPTER C86-44-U-NL.
6. COBRA CONNECTOR AND GROUND ROD.



**DAVID EVANS  
AND ASSOCIATES INC.**

**STANDARD DETAIL**

NTS

**RESIDENTIAL CONNECTION  
(DI WATER MAIN)**



Water District No. 90

Rev. Date  
04/2025

DETAIL NO.

**3A**